

Light efficiency:

127 Lumen/Watt

Light quality:

CRI: 95,0

Color temperature:


3460 K

Output: 4274 lm

Peak: 2021 cd

Power: 33,6 W

PF: 0,96



Tracking number: [n/a](#)

Product name:

Plata CCT Dipswitch 620x620 3500k 35W

Item number:


Date and time:

31-5-2023 09:42:51

Description:

PL-6262BL-H-365

3.10.0538 Driver 900mA




Beam angle

86,7°






CIE 1931
x: 0,409
y: 0,394

Spectra




Power






TM-30: 92,2



CRI: 95,0 (R1-R8)



CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
97,4	95,8	92,8	95,8	96,2	94,9	95,7	91,3	74,9	88,4	94,4	78,0	96,7	94,9	94,2


TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
93,0	95,6	91,5	94,4	92,7	92,6	95,5	95,9	96,1	92,4	87,9	88,0	90,7	88,3	90,2	87,6

CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
92,0	97,3	88,2	91,7	95,2	92,9	92,7	97,0	97,5	94,9	96,4	97,4	98,1	93,2	92,2

CQS: 93,8



Color parameters

Color temperature	Color rendering index	Red component	Color fidelity	Color gamut	Color quality scale	Color coordinate cie 1931	Color coordinate cie 1931	Color coordinate	Color coordinate	Color deviation from black body
CCT	CRI	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
3460 K	95,0	74,9	92,2	101,6	93,8	0,409	0,394	0,237	0,342	0,0007







Rf 92,2


Fidelity index Rf

Rg 101,6

Gamut index Rg

Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	93	-4%	-1%
2	96	-2%	1%
3	92	-1%	4%
4	94	0%	3%
5	93	0%	3%
6	93	4%	2%
7	95	1%	-1%
8	96	1%	-1%
9	96	-1%	0%
10	92	-2%	4%
11	88	2%	8%
12	88	5%	1%
13	91	4%	-5%
14	88	6%	-7%
15	90	2%	-7%
16	88	0%	-8%





Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
2021lx	505lx	225lx	126lx	81lx	56lx	41lx	32lx	25lx	20lx	17lx	14lx	12lx	10lx	9lx	8lx	7lx	6lx	6lx	5lx
187,7fcd	46,9fcd	20,9fcd	11,7fcd	7,5fcd	5,2fcd	3,8fcd	2,9fcd	2,3fcd	1,9fcd	1,6fcd	1,3fcd	1,1fcd	1fcd	0,8fcd	0,7fcd	0,6fcd	0,6fcd	0,5fcd	0,5fcd

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
2021	2010	1979	1934	1871	1789	1681	1504	1211	922	714	527	377	287	224	170	123	72	17	6
100%	99%	98%	96%	93%	89%	83%	74%	60%	46%	35%	26%	19%	14%	11%	8%	6%	4%	1%	0%

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
2021	2010	1979	1934	1871	1789	1681	1504	1211	922	714	527	377	287	224	170	123	72	17	6
100%	99%	98%	96%	93%	89%	83%	74%	60%	46%	35%	26%	19%	14%	11%	8%	6%	4%	1%	0%

Intensities in 180° c-plane


0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
2021	2010	1979	1934	1871	1789	1681	1504	1211	922	714	527	377	287	224	170	123	72	17	6
100%	99%	98%	96%	93%	89%	83%	74%	60%	46%	35%	26%	19%	14%	11%	8%	6%	4%	1%	0%

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
2021	2010	1979	1934	1871	1789	1681	1504	1211	922	714	527	377	287	224	170	123	72	17	6
100%	99%	98%	96%	93%	89%	83%	74%	60%	46%	35%	26%	19%	14%	11%	8%	6%	4%	1%	0%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
86,7°	143,9°	173,7°	86,1%	67,3%

iso-candela diagram




10%	202 cd
20%	404 cd
30%	606 cd
40%	808 cd
50%	1010 cd
60%	1212 cd
70%	1414 cd
80%	1617 cd
90%	1819 cd

Conditions:

Number of c-planes: 8

Candela at center: 2021 cd

iso-lux diagram



3%	0,606 lx
5%	1,01 lx
10%	2,02 lx
30%	6,06 lx
50%	10,1 lx

Conditions:

Number of c-planes: 8

Lux at center: 20,2 lx

*Lux distribution on a surface
when lamp is mounted at 10
meters from the surface.*

Glare evaluation according to UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	15,7	16,7	15,9	17,0	17,2	15,7	16,7	15,9	17,0	17,2
	3H	16,4	17,5	16,9	17,8	18,0	16,4	17,5	16,9	17,8	18,0
	4H	16,9	18,0	17,3	18,2	18,5	16,9	18,0	17,3	18,2	18,5
	6H	17,5	18,4	17,8	18,7	19,1	17,5	18,4	17,8	18,7	19,1
	8H	17,7	18,6	18,0	18,9	19,3	17,7	18,6	18,0	18,9	19,3
	12H	17,9	18,7	18,3	19,1	19,6	17,9	18,7	18,3	19,1	19,6
4H	2H	15,9	16,9	16,3	17,2	17,5	15,9	16,9	16,3	17,2	17,5
	3H	17,1	17,9	17,5	18,3	18,7	17,1	17,9	17,5	18,3	18,7
	4H	17,6	18,4	18,1	18,9	19,4	17,6	18,4	18,1	18,9	19,4
	6H	18,3	19,1	18,8	19,4	19,8	18,3	19,1	18,8	19,4	19,8
	8H	18,6	19,3	19,1	19,7	20,1	18,6	19,3	19,1	19,7	20,1
	12H	18,9	19,5	19,4	19,9	20,4	18,9	19,5	19,4	19,9	20,4
8H	4H	17,9	18,6	18,4	19,0	19,4	17,9	18,6	18,4	19,0	19,4
	6H	18,8	19,3	19,3	19,8	20,3	18,8	19,3	19,3	19,8	20,3
	8H	19,2	19,7	19,8	20,2	20,9	19,2	19,7	19,8	20,2	20,9
	12H	19,7	20,0	20,3	20,5	21,2	19,7	20,0	20,3	20,5	21,2
12H	4H	17,9	18,5	18,4	18,9	19,4	17,9	18,5	18,4	18,9	19,4
	6H	18,9	19,3	19,4	19,9	20,5	18,9	19,3	19,4	19,9	20,5
	8H	19,4	19,8	20,0	20,3	20,9	19,4	19,8	20,0	20,3	20,9
Variation of the observer position for the luminaire distance S											
S = 1.0H		0,1 / -0,2					0,1 / -0,2				
S = 1.5H		0,4 / -0,5					0,4 / -0,5				
S = 2.0H		0,9 / -0,7					0,9 / -0,7				
CIE 117-1995. Corrected glare indices referring to 4274 lm total luminous flux											

Coefficients of Utilization

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	110	106	102	98	107	103	100	97	99	96	94	95	93	90	91	89	88	86
2	101	94	88	83	99	92	87	82	88	84	80	85	81	78	82	79	76	74
3	94	84	77	71	91	83	76	70	80	74	69	77	72	68	74	70	67	65
4	87	76	68	62	84	74	67	61	72	66	61	70	64	60	67	63	59	57
5	80	69	61	55	78	68	60	54	65	59	54	63	57	53	61	56	52	50
6	75	63	54	49	73	62	54	48	60	53	48	58	52	47	56	51	47	45
7	70	57	49	44	68	56	49	43	55	48	43	53	47	43	52	46	42	40
8	65	53	45	39	64	52	44	39	51	44	39	49	43	39	48	43	38	37
9	61	49	41	36	60	48	41	36	47	40	35	46	40	35	45	39	35	33
10	57	45	38	33	56	45	37	33	43	37	32	43	37	32	42	36	32	30

LAMPS (number of lamps)

Luminaire budgetary diagram




Zonal Lumen Summary

0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
{LUM0-10}	546 lm	823 lm	932 lm	715 lm	474 lm	290 lm	180 lm	77,7 lm
90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
8,24 lm	6,34 lm	6,68 lm	6,54 lm	6,04 lm	5,20 lm	4,20 lm	2,63 lm	0,908 lm


LCS table

BUG rating:	B2 U2 G1	
Forward light	Lumens	Lumens %
Low(0-30):	779,6	18,2%
Medium(30-60):	1060,5	24,8%
High(60-80):	234,7	5,5%
Very high(80-90):	39	0,9%
Back light		
Low(0-30):	779,6	18,2%
Medium(30-60):	1060,5	24,8%
High(60-80):	234,7	5,5%
Very high(80-90):	39	0,9%
Uplight		
Low(90-100):	8,4	0,2%
High(100-180):	38,5	0,9%

LCS graph



Warmup curve



Warmup result

Warmup time:	Lamp stabilized in 15 min 2 sec
Warmup variation	-0,2%

Warmup conditions

Stable period:	15 min
Stable change max:	2,0%
Minimum time:	15 min

Color temperature change

CCT start	CCT change	CCT end
3462 K	-2 K	3460 K


Output change

Output start	Output change	Output end
4281 lm	-7 lm	4274 lm


Flicker curve (complete sampled flicker signal)



Flicker frame (frame of one flicker period)



Flicker FFT (frequency scope of flicker curve)



Flicker results:

Flicker frequency:		n/a Hz	
Flicker index:	n/a	JA8/10 40Hz	n/a %
Flicker percentage:	n/a %	JA8/10 90Hz	n/a %
SVM: (Visual flicker)	n/a	JA8/10 200Hz	n/a %
PstLM	n/a	JA8/10 400Hz	n/a %
Mp	n/a	JA8/10 1000Hz	n/a %

Flicker conditions:

Sample rate:	n/a samples/second
--------------	--------------------